



आईएसओ 9001-2015 पत्तन
AN ISO 9001-2015 PORT

MORMUGAO PORT AUTHORITY
ENGINEERING MECHANICAL DEPARTMENT
ELECTRICAL HARBOUR (HEADLAND) SECTION

NOTICE INVITING BUDGETORY OFFERS

Name of Work	“SITC OF EARTH STATIONS FOR VARIOUS INSTALLATIONS IN PORT AREA”
Date of submission of budgetary quotation	On or Before 07.07.2023 at 15.00 Hrs.
Address for communication:	Executive Engineer (E-HR), 2nd floor, Mechanical Engineering Department, Mormugao Port Authority, Admin. Building, Headland sada Vasco-de-Gama Goa - 403804
Contact Details	Phone : (0832) 2594207, 2594271 Email : mohamed.shaik@mptgoa.gov.in
Website	www.mptgoa.gov.in

EXECUTIVE ENGINEER (E-HR)
MORMUGAO PORT AUTHORITY



आईएसओ 9001-2015 पत्तान
AN ISO 9001-2015 PORT

MORMUGAO PORT AUTHORITY
ENGINEERING MECHANICAL DEPARTMENT
ELECTRICAL HARBOUR (HEADLAND) SECTION

Sub: "SITC OF EARTH STATIONS FOR VARIOUS INSTALLATIONS IN PORT AREA"

Ref: Budgetary Quotation No. CME/XEN(E-HR)/HL03/

Mormugao Port Authority intends to carryout work of **"SITC OF EARTH STATIONS FOR VARIOUS INSTALLATIONS IN PORT AREA"**.

As such, it is requested to kindly furnish budgetary quotation for the same (Scope of work, technical specifications are enclosed at Annexure-I and Price Schedule enclosed at Annexure- II.

Your budgetary quotation should reach to this office on or before **07.07.2023** at **1500** Hrs.

Thanking you,

Yours sincerely,

EXECUTIVE ENGINEER (E-HR)



आईएसओ 9001-2015 पत्तन
AN ISO 9001-2015 PORT

MORMUGAO PORT AUTHORITY
ENGINEERING MECHANICAL DEPARTMENT
ELECTRICAL HARBOUR (HEADLAND) SECTION

ANNEXURE-I

**TITLE OF WORK: “SITC OF EARTH STATIONS FOR VARIOUS INSTALLATIONS IN
PORT AREA”**

TECHNICAL SPECIFICATIONS

1. GENERAL

Mormugao Port Authority proposes to provide earth stations for various installations in port area in accordance with IS 3043 and as per technical specifications:

2. SCOPE OF WORK

- a. The scope of work shall be Providing Earthing for various installations in Port area complete with G.I. earth plate electrode 600mmX600mmX6.0mm thick buried into the ground with its face vertical at a depth of not less than 3 meters from ground level, filled with alternate layer of common salt and charcoal and connected to G .I. earth strip 50mm X 6 mm thick by means of SS nuts bolts and Washers, including necessary PCC earth pit chamber size 450mm X 450mm with cast iron chamber cover having suitable arrangement for lifting, watering arrangement shall be made with funnel having mesh suitably earthed. All the material required to complete the work has to be supply by the contractor.
- b. Each of the Earth pit cover shall be duly painted and identified with earth pit number, name of Equipment, neutral or body Earthing, date of testing, individual pit resistance value and due date for measurement.
- c. The contractor shall Supply GI strip of size 50mm x 6 mm The laying of GI strip to be done above the ground and should be connected to neutral and body of the equipment with SS bolts, nuts & washers. Interconnections and joints for earth conductors shall be carried out using SS material only. Sharp bends required in GI strip should be formed by the use of a bending machine. Earthing Strips which are installed below the ground should be covered adequately with insulating Sleeve to avoid corrosion. For installing GI strip on wall, GI clamps to be used for every one meter.



आईएसओ 9001-2015 पत्तान
AN ISO 9001-2015 PORT

MORMUGAO PORT AUTHORITY
ENGINEERING MECHANICAL DEPARTMENT
ELECTRICAL HARBOUR (HEADLAND) SECTION

- d. The necessary tools and tackles, material and labour required for all the works mentioned hereunder to complete the works upto the satisfaction of Port engineer, is in the scope of the contractor.
- e. Excavation shall be carried out by taking extreme precaution so as not to damage any cable in the vicinity. After excavation broken lumps and stones, if any, are to be removed from the earth pit.

3. MEASUREMENT OF EARTH PIT RESISTANCE:

- a. The job includes measurement of resistance of the new earth pits after installation using earth tester. Copy of valid calibration certificate of the above earth tester and earth testing certificate has to be provided to the Port.
- b. The values shall be tabulated and submitted to Engineer-in-charge.
- c. The individual earth pit resistance value shall be < 5 ohms, earth pits measuring higher than 5 ohms are liable for rejection.
- d. Testing of earth pit shall be carried out in the presence of Engineer – In charge or his representative.

4. TECHNICAL SPECIFICATION:

Provision of earth stations for various installations in port area in accordance with IS 3043 and as per technical specifications.

5. SPECIAL TERMS AND CONDITION:

- i. The contractor at his own cost may visit MPA site, before quoting for the tender.
- ii. Power supply shall be provided to contractor free of cost at the nearest available point.
- iii. In some locations, the work may be carried out near Live High voltage bus bars/lines, contractor has to follow all safety rules & regulations etc. and guide his manpower for safe working
- iv. All the material required for execution of the work has to be arranged by contractor at his own cost. Connecting new earth pits to existing pits / main earth grid is in the scope of the contractor.



आईएसओ 9001-2015 पत्तान
AN ISO 9001-2015 PORT

MORMUGAO PORT AUTHORITY
ENGINEERING MECHANICAL DEPARTMENT
ELECTRICAL HARBOUR (HEADLAND) SECTION

ANNEXURE-II

Name of the Tender: **SITC OF EARTH STATIONS FOR VARIOUS INSTALLATIONS IN PORT AREA**

Sr. No.	Description of work	Unit	Qty.	Rate per Unit (Rs.)	Amount (Rs.)
1.	SITC of Earthing Pits for various installations in port area as per Technical specification	No	1		
2	Supply and laying of GI strip size 50mm x 6 mm	RM	1		
	Total				

(In words Rupees _____
_____ only)

- Note:** 1) The rates quoted above shall be exclusive of GST.
2) Applicable GST shall be paid to the concerned authority by the Contractor and documentary evidence of the same shall be produced to MPT for reimbursement at actual