MORMUGAO PORT AUTHORITY ENGINEERING MECHANICAL DEPARTMENT

Name of the tender: "Augmentation of firefighting facilities at berth no.8 of Mormugao Port Authority on turnkey basis".

TENDER NO.: CME/PD/II/2024

ADDENDUM - III

CORRECTIONS / ADDITIONS / DELETIONS, ETC...

[Total Number of Pages: 1]

NOTE:

- This "Addendum" should be read in conjunction with Tender Document reference no. CME/PD/II/2024
- 2. The due date of submission of tender has been extended to 05.02.2024 at 11.30 hrs. and opening of tender on 06.02.2024 at 11.30 hrs.
- 3. All other terms and conditions of the Tender Document will remain unchanged.
- 4. One set of this "Addendum", along with one set of Tender Document, shall be submitted along with the Tender (in Cover-I), duly signed and stamped, as token of acceptance.

AMENDMENT TO CLAUSES

Name of the tender: Augmentation of firefighting facilities at berth no.8 of Mormugao Port Authority on turnkey basis

Tender No.: CME / PD / II / 2024

SR. NO.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	AMENDMENT
1	BOQ (E-13)	126/211	100KVA with roof sheet, suitable of marine application. Engine MOC-Duplex, Radiator cooled with exhaust piping, the exhaust pipe shall be insulated as per existing design.	Supply, Installation, Testing and commissioning of DG Set 100KVA with roof sheet, suitable of marine application. Engine MOC- Cast Iron or as per manufacturer recommendations. Radiator cooled with exhaust piping, the exhaust pipe shall be insulated as per existing design.
2	BOQ (D16)		Supplying, laying, testing and commissioning of Perforated type cable tray with necessary bands, tees and clamps for fixing. All material shall SS 316. Cable Trays shall be considered with Double Coupler Plates. All Bolts shall be SS 316. Thickness of the cable tray material shall be 6 mm for 300 mm & above & 4 mm for below 300 mm size.	Tender condition prevails. However, thickness of the cable tray material shall be taken as 3 mm.
3	BOQ (D29, D34,E18)	125/211, 127/211	Supply & Fixing of Perforated type cable tray with necessary bands, tees and clamps for fixing. All material shall be GI. Cable Trays shall be considered with Double Coupler Plates. All Bolts shall be SS 316 .Thickness of the cable tray material shall be 6 mm for 300 mm & above & 4 mm for below 300 mm size.	