## MORMUGAO PORT TRUST ENGINEERING (CIVIL) DEPARTMENT

## **TENDER NOTICE NO.: CE/N-27/2016**

TENDER NOTICE NO.: CE/28/2016: SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 2 NOS. OF ELEVATORS FOR CRUISE TERMINAL BUILDING AT MORMUGAO HARBOUR

## REPLIES TO THE QUERIES RAISED DURING THE PRE BID MEETING HELD ON 12.04.2016

0	Olamas Na	Oversia a finansa halada sa	MDTI- Decrees
Sr.	Clause No.	Queries from bidders	MPT's Response
No.	ANNEXCIPETA	1.6	5
1.	ANNEXURE I-A  1.2 operating conditions (salient performance requirement) 2.09  Page 71	Lift opening in car is shown as 700 mm width and placed centrally. This width opening is not sufficient for a physically handicapped person. With similar car dimensions with 800 mm car opening placed on sides for lift with	Please note that in the given lift specification, door opening shall be "as per IS 14665" which states for given capacity and dimension, door opening entrance to be 800 mm. All details shall be as per IS 14665
		machineless room.	specification.
2.	ANNEXURE I-A  SPECIFIC REQUIREMENTS FOR ELEVATOR  1.1 Page 70	Annexure I-A,1.1, specific requirements for elevator mentions 1 No. of each, ACVVVF control, <b>Duplex</b> full collective and selective type, whereas in 1.2, operating conditions (salient performance requirement) 3.02 mentions Type of operation as <b>Simplex</b> full collective and selective with / without attendant. Kindly Confirm	ANNEXURE I-A  SPECIFIC  REQUIREMENTS FOR  ELEVATOR  1.1 is revised as follows:  1.1 1 No. of each, ACVVVF control, Simplex full collective and selective type, as per details in the enclosed drawing
3.	Additional specifications Clause No. 4.11 page 49	i	Braille push buttons to be provided in lift car and at each landing as per Central Government regulations.