

SI. No.	CLAUSE. NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
1	2.1(C)	15	Lamps at Sr. no. 3 and 4 in the table given below are to be fixed in such a way that the tube light shall match with the existing fitting of base G13 and CFL shall match with the base b22 and if not, to change the base as per the requirement of LED lamps.	For above serials the existing Tubelights/CFL is asked to be replaced with LED Tubelight/BULB. But as per the section-II SCOPE OF WORK 2.1 c the LED fittings, if not matching the existing base , the entire fitting to be replaced. How will the extra cost (material+labour) of fitting to be paid to contractor.	Tender condition prevails, However if required, new holder/base will be supplied by the Port. .