

MORMUGAO PORT TRUST MATERIALS MANAGEMENT DIVISION ENGINEERING (MECHANICAL) DEPARTMENT 14.06.2021

MM/NS/CME/0063

To.

Ellora Enterprises, Vasco.

Weld Engineers, Ponda.
 Delta Trading, Panaji.

4. Kakode Trading LLP, Margao.

5. Darshana Enterprises, Vasco.

6. A.M. Ventures, Vasco.

7. Solas Fire & Safety, Panaji.

8. Vintex Fire Protection, Mumbai.

9. Oust Fire Safety Engineers, Navi Mumbai.

10. Intime Fire Appliances, Mumbai.

11. Meecas Engineering, Margao.

12. Rolex Engg. & Trading Co., Vasco.

13. R.S. Casodcar & Co., Margao.

14. Bashir A.I. Khan, Vasco.

15. A.G. Gauge Repairs, Vasco.

16. House of Safety, Vasco.

17. Super Safety Services, Mumbai.

18. HD Fire Protect, Thane.

19. Vinit Fire & Safety Equipment, Pune.

Dear Sir,

Sub:-Enquiry No. MM/NS/CME/0063.

You are requested to kindly furnish your best offer for the subject items in the following format:-

Sr. No.	Description	Qty.	Basic (all incl.) Unit Rate (except GST) (Rs.)	GST/ Unit (Rs.)	FOR Destination Amount/Unit (Rs.)	HSN Code & Brand Offered
1.	Supply of flashback arrestor for cylinder regulator on Oxygen line (See Annexure for Technical Specifications attached).	2 Nos.				
2.	Supply of flashback arrestor for cylinder regulator on Acetylene/LPG line (See Annexure for Technical Specifications attached).	2 Nos.				
3.	Supply of flashback arrestor for cutting torch on Oxygen line (See Annexure for Technical Specifications attached).	2 Nos.				
4.	Supply of flashback arrestor for cutting torch on Acetylene/LPG line (See Annexure for Technical Specifications attached).	2 Nos.				

TERMS & CONDITIONS

- 1. **PAYMENT:** Kindly note that we are a Govt. of India organization, and as such our payment shall be 100% payment within 30 days of receipt of material/invoice/documents by ECS/EFT/RTGS. Suppliers Invoice should indicate the suppliers and MPT's GST numbers, and the HSN number. Confirm acceptance.
- 2. **DELIVERY:** The delivery period is within 4 weeks. You will have to deliver the material, duly insured at your cost on FOR Destination basis, upon receipt of our firm order. <u>Confirm acceptance</u>.
- 3. **VALIDITY:** Your quotation should be valid for 60 days from the date of opening.
- 4. **PART QUANTITIES:** As the material is regarding safety of the workers, the whole requirement will be procured from the overall lowest bidder.
- 5. **TECHNICAL SPECIFICATIONS:** As per attached ANNEXURE-A. <u>Confirm acceptance</u>. Indicate deviations in the offer, if any.
- 6. **SECURITY DEPOSIT:** Within 14 days of acceptance of the tender, the successful tenderer will have to effect a Security Deposit amount equal to 3% of the basic value, exclusive of GST, by Demand Draft or by Bank Guarantee from a Scheduled Bank. The Demand Draft should be drawn in favour of the Financial Advisor and Chief Accounts Officer, Mormugao Port Trust, Goa payable at Mormugao Harbour, Goa. In case the Security Deposit is furnished by way of Bank Guarantee, the same should be valid for a minimum period of 5 years with a claim period of further 3 months, till the Guarantee Period of the material supplied. Please note that we do not accept Bank Guarantee issued by ICICI Bank.

Web Site: https://mptgoa.gov.in/ E-Mail mm@mptgoa.gov.in

- 7. **LIQUIDATED DAMAGES**: Supply schedule as per order should be strictly adhered to. In the event of delay in supplies, Liquidated Damages at 0.5% of the total basic value of the undelivered quantity will be levied per week or part thereof of delay. The total Liquidated Damages shall however not exceed 10% of the total basic value of the order. The total value here means the total value of the order exclusive of taxes. **The date of receipt of material at our Stores at Baina, Vasco will be considered as date of delivery for the purpose of Liquidated Damages.**
- 8. **FORCE MAJEURE & EXTENSION IN DELIVERY PERIOD**: In case of failure to deliver the goods in time which shall have arisen due to war, insurrection, restraint imposed by the Government Act or Legislation or other Authority, accident, strike, riot, lock-out or unforeseen events beyond human control directly or indirectly interfering with the supplies of stores or from any cause which the purchaser may admit as reasonable ground for an extension of time, the purchaser will allow such additional time he considers reasonable provided that the contractor shall report to the purchaser the occurrence of any cause as aforesaid which will or might affect the performance of the contract within a reasonable time. Requests for extension received after expiry of the delivery schedule will not be entertained.

Kindly furnish your typed offer in sealed cover marked "MM/NS/CME/0063 due on 23.06.2021", which shall be opened on 23.06.2021 at 15.30 hrs. The cover (offer) should reach this office latest by 15.00 hrs on the due date.

Offer may also be sent by e-mail, before the due date and time, if you wish so.

Thanking you,

Yours faithfully,

DY. MATERIALS MANAGER

Encl.: 1 folio of Technical Specifications.

Web Site: https://mptgoa.gov.in/ E-Mail mm@mptgoa.gov.in

ANNEXURE-A

Detailed Technical Specifications for Dry Type Flashback Arrestor (FBA)

Sr. No.	Specifications	Gas 1	Gas 2
1	Type of Gas used	Oxygen	Acetylene\LPG
2	Type of thread connections. Should directly coupled to Regulator\Torch	i) Regulator –G 3\8 RH ii) Cutting Torch-G 3\8 RH	i) Regulator –G 3\8 LH ii) Cutting Torch-G 3\8 LH
3	Arrestor Housing	Brass	Brass
4	Max working Pressure	20 Bar	5 Bar
5	Size & weight	 i) Regulator App. 24diax82 mm length, Wt. App.190gms. ii) Torch24diax65 mm length, Wt. App.107gms 	i) Regulator App. 24diax82 mm length, Wt. App.190gms. ii) Torch24diax65 mm length, Wt. App.107gms
6	i) Non return valve(NV) ii) Flame arrestor(FA) iii) Thermal Cut off (TV)	i) Non return valve(NV) ii) Flame arrestor(FA) iii) Thermal Cut off (TV)	i) Non return valve(NV) ii) Flame arrestor(FA) iii) Thermal Cut off (TV)
7	Colour code	Blue	Red
8	Maintenance	Maintenance free	Maintenance Free
9	Warranty	More than 5 years	More than 5 years
10	Insurance coverage in case of failure of FBA	Comprehensive general liability	Comprehensive general liability
11	Conform to	DIN ISO 5175	DIN ISO 5175

Note:-

- 1. Supplier should inspect\check the type of Regulator and Cutting Torch being used by Port to ensure that the FBA can be installed on it before quoting\supplying.
- 2. Necessary test certificates for the FBA should be submitted.
- 3. Supplier should give demonstration regarding the use of FBA to the Port staff after supply.

DY. MATERIALS MANAGER

Web Site: https://mptgoa.gov.in/ E-Mail mm@mptgoa.gov.in