

MORMUGAO PORT TRUST
ENGINEERING MECHANICAL DEPARTMENT

E-TENDER FOR “ INSTALLATION, TESTING AND COMMISSIONING OF 30 MTR HIGH MASTS AT RAILWAY PLATFORM / YARD AT MPT”

e-TENDER NO: **CME/PROJECT/HIGHMAST/2017/04**

ADDENDUM

CORRECTIONS / ADDITIONS / DELETIONS, ETC...

[Total Number of Pages: 1]

NOTE :

1. This “Addendum” should be read in conjunction with Tender Document reference no. **CME/PROJECT/HIGHMAST/2017/04**.
2. Consequential changes, arising out of this Addendum, will be deemed to have been effected, even if the same were not incorporated specifically in the Tender Document.
3. The date for submission of the Tender and Opening of Cover – I is as detailed at NIOT
4. All other terms and conditions of the Tender Document will remain unchanged.
5. One set of this “Addendum”, along with one set of Tender Document, shall be uploaded along with the Techno-Commercial Offer (in Cover-I), with each page, duly signed and sealed, as acknowledgement of acceptance.

PRE-BID CLARIFICATIONS - Tender No. CME/PROJECT/HIGHMAST/2017/04

PRE BID QUERIES OF “INSTALLATION, TESTING AND COMMISSIONING OF 30 MTR HIGH MASTS AT RAILWAY PLATFORM / YARD AT MPT”

Sr. no	Reference No in the tender	Page No.	Tender Conditions	Queries / Comments & Suggestions with relevant reasons / remarks	Port's Clarification
1.	2.2.1	18	The Port shall supply refurbished Highmasts and the successful bidder will be required to erect, install and commission such refurbished Highmasts as per the layout drawing enclosed.	<ol style="list-style-type: none"> 1. Foundation bolts and template will be provided by whom and if required drawing to be supplied showing exact no. of bolts and PCD to be issued. 2. As the scope of work is only ITC of highmast we understand highmast, all required accessories including foundation bolts etc will be made available at the individual location to us at the time of work. 	All the Highmasts and its accessories will be provided by the Port including foundation Bolts and templates.
2.	2.3.1 2.3.2	19 20	<p>The components are to be interconnected for 3 phase and Neutral by suitably sized copper busbars and PVC sleeved with colour code.</p> <p>The suitable size and rating of electrolytic grade copper conductor/bus, phase to phase and Neutral with PVC sleeved colour code shall be provided.</p>	Please confirm whether busbar are plain copper busbar with PVC coloured sleeving or to be tin plated to prevent oxidation.	All Busbars shall be of copper tin plated and PVC sleeved with colour code.

3.	2.3.1	19	<p>All these components shall be mounted in the Load Point Panel by means of suitable hardware (nuts, bolts shall be of stainless steel).</p> <p>All the components shall be panel mounting type and hardware cadmium passivated and shall be provided with 2 Nos. SS terminals for earthing.</p>	Are all hardwares, hinges, angles, channels etc to be used are Stainless steel grade?	All hardwares shall be stainless steel and cadmium passivated.
	2.3.2	20	All the components shall be panel mounting type and hardware cadmium passivated and shall be provided with 2 Nos. SS terminals for earthing.		
4.	2.3.7	24	The earth connection shall be made of GI strip of 50 X 6 size conforming to IS 3043	Earthing strip to be supplied standard galvanised strip or "Hot Dip" galvanised?	Earthing strip shall be "Hot Dip" galvanised

TENDER DOCUMENT CHANGES

Sr. no	Reference No in the tender	Page No.	Tender Conditions	Clarification
1.	NIOT	6	Contact Details: For Tender related queries: Ph 08322521170	Contact Details: For Tender related queries:Ph 0832-2594229/69/08
2.	3.37	49	ARBITRATION: The arbitration proceeding shall take place in Goa or at Administration Building, MPT only, and the same shall be under jurisdiction of High Court of Goa.	<p>ARBITRATION: In addition to what has been stated in CI 3.35 in this tender document on this issue, the following may be noted by the Tenderer.</p> <p>a)Failing amicable settlement the dispute or differences or claims as the case may be, shall be finally settled by binding arbitration under the Arbitration and Conciliation Act, 1996 including all amendments thereof. The arbitration shall be by a sole Arbitrator and Port shall appoint an Arbitrator for Arbitration. The Arbitrator shall complete the entire proceedings within a period of one year. However the arbitration fee to be borne equally by both the parties.</p> <p>b) The arbitration proceeding shall take place in Goa or at Administration Building, MPT only, and the same shall be under jurisdiction of High Court of Goa.</p>
3.	3.53	52	LIQUIDATED DAMAGE: In the event of failure by the contractor to complete the execution of the work within the time stipulated in the contract or by the expiry of any period of extension granted by the Board's terms thereof, the contractor shall pay the Board as Liquidated Damages for delay to complete the work, a sum of 1% of contract price per week or part thereof subject to a maximum of 10% and the Board shall have the power to deduct this amount from the payment of the amounts due to the contractor or from his deposit	LIQUIDATED DAMAGE: In the event of failure by the contractor to complete the execution of the work within the time stipulated in the contract or by the expiry of any period of extension granted by the Board's terms thereof, the contractor shall pay the Board as Liquidated Damages for delay to complete the work, a sum of 0.5% of contract price per week or part thereof subject to a maximum of 5% and the Board shall have the power to deduct this amount from the payment of the amounts due to the contractor or from his deposit.
4.	BOQ 5(ii)	57	Laying of LT cable in RCC trench, testing and commissioning.	Laying of LT cable in RCC trench/pipe (provided by Port), testing and commissioning.

