

MORMUGAO PORT TRUST
ENGINEERING MECHANICAL DEPARTMENT

Tender no. CME/XEN (E-HR)/H16/2021/03



An ISO 9001 : 2008 Port
ISPS CODE Compliant

TENDER FOR

**“Providing of Power supply points for portable Mist Cannon at
B. No. 10/11 area and excavation of 12 meters trench for rectification
of damaged power supply cable of High Mast No. 32”**

Due at **15.00hrs** on 15/07/2021

Website: www.mptgoa.gov.in

MORMUGAO PORT TRUST
ENGINEERING MECHANICAL DEPARTMENT

Tenders are invited in single cover system eligible contractors/firms duly super scribed as
TENDER FOR “Providing of Power supply points for portable Mist Cannon at B. No 10/11 areas and excavation of trench of 12 meters in length for rectification of damaged power supply cable of High Mast No. 32”

Details about Tender:

Tender invited by	CHIEF MECHANICAL ENGINEER/ MORMUGAO PORT TRUST
Tender No.	CME/XEN(E-HR)/H16/2021/03
Name of Work	“Providing of Power supply points for portable Mist Cannon at B. No 10/11 areas and excavation of trench of 12 meters in length for rectification of damaged power supply cable of High Mast No. 32”.
Completion Period	The work should be completed within 45 days from the 7 th day of receipt of LOA/P.O whichever is earlier.
Liquidated Damages	In the event of failure by the contractor to complete the execution of the work within the time stipulated in the contract or by the expiry of any period of extension granted by the Board’s terms thereof, the contractor shall pay the Board as Liquidated Damages for delay to complete the work, a sum of 0.5% of contract price per week or part thereof subject to a maximum of 5% and the Board shall have the power to deduct this amount from the payment of the amounts due to the contractor or from his deposit. The GST @ 18% on LD will be deducted at the time of making payment to Vendors/ Contractors..
Payment terms	100% payment shall be made within 15 days after satisfactory completion and commissioning of work and on furnishing undisputed invoice complete in all respects. The contractor shall furnish their GST code, EPF, ESI, Wage register, Attendance register, PAN card, bank account number, MICR number Name of the Branch along with Bill for arranging payment made through E.C.S. by the Port.
Bid Security Declaration (BSD)	Bidder should arrange for the Bid Security declaration as enclosed at APPENDIX-III . The original BSD should be enclosed along with tender while submitting bid. The BIDDER shall submit the Bid Security Declaration Format in lieu of EMD. The tender not accompanied with Bid security declaration shall be summarily rejected.
Bid Validity	60 Days from the date of opening of the tender
Date of submission of bids	15/07/2021 till 15:00 Hrs.
Date of Opening of bids	15/07/2021 at 15:30 Hrs
Address for communication and submission of bid:	XEN(E-HR) Second Floor, Admin. Bldg, Engineering Mechanical Dept., Mormugao Port Trust, Mormugao, Goa – 403804.
Contact Details	Phone :0832-2594216/4579 Mobile: 9423322588; Email : sunil.damodaran@mptgoa.gov.in
Website	www.mptgoa.gov.in

SUPERITENDING ENGINEER (E)

TECHNICAL SPECIFICATION

1.0. GENERAL

Mormugao Port Trust invites Tender in single cover system for the work of **“Providing of Power supply points for portable Mist Cannon at B. No 10/11 areas and excavation of trench of 12 meters in length for rectification of damaged power supply cable of High Mast No. 32”**

2.0. SCOPE OF WORK

The Scope of work involves:

1. Clamping of 4 core x 25 sq.mm Aluminum armoured cable on wall with GI clamps at 1 meter spacing. (Cable will be supplied by Port). Total length of cable in the wall is 120 meters.
2. Laying of 23 meters cable in excavated trench of size 0.4m wide and 0.8 m deep through GI pipe 3” dia. at road crossing. (GI pipe “B” class will be supplied by Port).
3. Laying of 5 meters cable on T-2 shed ramp through 3” dia. GI pipe with cementing on top (GI pipe “B” class to be supplied by Port).
4. Excavation of cable trench of length 35 meters of size 0.4mx0.8m deep in asphalted road and back filling at locations indicated by site engineer.
5. Supply, Installation and wiring of Distribution box mounted on MS angle stand 3 feet height, well grouted , containing 1 No.4 pole, 32 Amps MCB, 1 No. 32 Amps 5-pin wall mounted type IP44, Industrial socket and provision of 1 no. 15 Amps switch socket point inside DB. (DB should be grey painted and outdoor type with provision of glands for 4-core, 25 sq.mm cable). Termination of 4 core X 25 sqmm cable in DB. Testing and commissioning.
6. The locations of power point and excavation will be as indicated by the site Engineer.

3.0. GENERAL TERMS AND CONDITIONS

- 3.1. The Contractor shall commence and complete the work as per the BOQ and proper safety precautions should be taken at the electrically charged installation at the substation. The work is to be carried out as per the site conditions and relevant IS standards.
- 3.2. Work should be carried out to the satisfaction of the Engineer in charge. All left over/scrap materials, debris etc. are to be promptly cleared and remaining Port material like cable etc. have to be shifted from the work site to electrical workshop to MM Depot by the Bidder at his own cost and risk as per the directions of Engineer In Charge.

4.1. Eligibility of the Tenderer

The following should accompany the bid document in sealed cover, viz.

- i) The contractor should be experienced Electrical contractor having who has executed similar works in the past. A copy of completion certificate for having executed similar works shall be furnished along with the bid which shall be verified before award of LOA/P.O.
Similar works implies “laying of cables in any Govt. or reputed Private organisation”.
- ii) Tender document issued by the Port shall be duly initialled on each page with rubber stamp of the Bidder and submitted along with the bid.
- iii) Certificate of Registration with PF Commissioner/ESI authorities and GST.

- iv) Price Bid should be duly filled in. Bidders are advised to quote strictly as per the price bid.
- v) Appendix I, II, and III should be submitted duly filled in.

4.2. Validity:

The validity period of the offer shall be 60 days from the date of opening of the bid.

4.3. Price:

- i) The bidder shall quote the price exclusive of GST. Applicable GST shall be paid on the quoted price. The bidder shall indicate the applicable GST rate on the goods/services in the price bid.
- ii) Evaluation will be done considering only the basic price.

4.4. Bid Security Declaration (BSD)

Bidder should arrange for the Bid Security declaration as enclosed at **APPENDIX-III**. The original BSD should be enclosed along with tender while submitting commercial bid. The BIDDER shall submit the Bid Security Declaration Format in lieu of EMD. The tender not accompanied with Bid security declaration shall be summarily rejected.

4.5. Completion Period:

The entire work shall be completed within **45 days** from the 7th date of receipt of LOA/purchase order, whichever is earlier.

4.6. Payment Terms:

- i) 100% payment shall be made within **15 days** after satisfactory completion and upon successful commissioning of the work on furnishing undisputed invoice complete in all respects.
- ii) The contractor shall furnish their bank account details for the payment through ECS by the Trust. A copy of the PAN card, GST code, wage register, attendance register, EPF& ESI, Bank account number, MICR number, Name of the Branch along with Bills shall be furnished for arranging payment made through E.C.S. by the Trust.
- iii) The bidder shall quote GST No. of MPT (30AAALM0293P1ZY) on all invoices raised on Port. If bidder is not registered under GST or opted for composition scheme under GST, undertaking of the same shall be submitted by the bidder.

4.7. Liquidated Damages:

In the event of failure by the contractor to complete the execution of the work within the time stipulated in the contract or by the expiry of any period of extension granted by the Board's terms thereof, the contractor shall pay the Board as Liquidated Damages for delay to complete the work, a sum of 0.5% of contract price per week or part thereof subject to a maximum of 5% and the Board shall have the power to deduct this amount from the payment of the amounts due to the contractor or from his deposit. The GST @ 18% on LD will be deducted at the time of making payment to Vendors/ Contractors.

4.8. Other terms and conditions

- i. All tools and tackles and logistics involved in the work shall be arranged by the Contractor at their own cost. The transportation cost, if any, shall be borne by the contractor.

- ii. The Bidders are advised to visit the site and get acquainted with the quantum of the work involved and site conditions before quoting for the works.
- iii. The scope of work and bill of quantities at “**ANNEXURE-I**” to be read in conjunction to ensure the actual supply of materials and works involved.
- iv. Necessary Entry passes shall be obtained by the Contractor at their own cost with prior approval of the Port Officials on Duty.
- v. The Trust will not be responsible for any loss or damage to the materials/ tools/plants engaged by the contractor/bidder during the work at site or transportation.
- vi. The Contractor shall take utmost care during the execution of the work, if any damage caused to the Port property, the cost of the damage shall be recovered from the Contractor’s running A/c bill or may be recovered by the Board in any other mode as deemed fit.
- vii. The power supply shall be provided by the Port free of cost for execution of the work; however, the Contractor shall take power supply from the nearest source by making suitable arrangements at their own cost and risk.
- viii. Any work not mentioned herein above but necessary for overall completion of the work shall be deemed to be included in the scope of work without any additional financial implications to the Port, whatsoever.
- ix. Under any circumstances, if the work is abandoned by the contractor for whatever reasons, the same shall be executed for successful commissioning ‘thro’ the external agency to be engaged by the Port at the risk and cost of the contractor. The expenditure incurred by the Port in this regard shall be recovered from the monies due to the contractor / security deposit or as deemed fit by the Board.
- x. The works shall be carried out with due regard to safety standards prevailing in the Port.
- xi. All the workmen shall be covered under a suitable insurance policy. Accidents, if any, fatal or otherwise at site shall be the sole responsibility of the contractor. The Port should not be held liable for compensation in whatsoever manner under any circumstances.
- xii. Further amendments if any, visit our Website www.mptgoa.gov.in.

EXECUTIVE ENGINEER (E-HR)

BANK DETAILS FOR ECS PAYMENT

1. Name of the Bank and Branch :
2. Account Number :
3. MICR Number :
4. Type of Account :
5. IFSC Number :
6. Copy of PAN Card :
7. TIN Number :
8. GST Regn. No.:
9. EPF No. :
10. ESI Regn. No.

Firm's Sign and Seal

Place:

Date:

MORMUGAO PORT TRUST, GOA		
1	Income Tax PAN No.	AAALM0293P
2	GST TIN (Provisional ID Number)	30AAALM0293P1ZY
Vendor GST Details		
1	Business Name	
2	Constitution of Business	
3	Name of Proprietor/Partners/Directors	
4	Principal Place of Business	
5	Name of Responsible Person	
6	Email	
7	Telephone Number	
8	Mobile	
9	Additional Place of Business	
(i)	Email	
(ii)	Telephone Number	
(iii)	Mobile	
10	Income Tax PAN No.(Attached Certified Copy)	
11	GST ID No./Provisional ID No.(Attached Certified Copy)	

I, Mr. Mrs. _____ of _____ M/s. _____ do certify that the information given above is complete and correct.

Signature

Name: _____ Place: _____

Date :

Bid Security Declaration Form

Date: _____ Tender No. _____

To,
CHIEF MECHANICAL ENGINEER
MPT Goa.

Sub: Tender for **“Providing of Power supply points for portable Mist Cannon at B. No 10/11 area and excavation of 12 meters trench for rectification of damaged power supply cable of High Mast No. 32.”**

I/We understand that, according to tender conditions, bids must be supported by a Bid Securing Declaration.

I/We accept that I/We may be disqualified from bidding for any contract with MPT for a period of three (3) year from the date of notification if I am /We

- a. Are in a breach of any obligation under the bid conditions,
- b. Made misleading or false representations in the forms, statements and attachments submitted in proof of the qualification requirements;
- c. If the bid is withdrawn or varied or modified in a manner not acceptable to the Employer during the validity or extended validity period duly agreed by the Bidder
- d. Any effort by the Bidder to influence the Employer on bid evaluation, bid comparison or contract award decision.
- e. Fail to commence the work on the specified date as per LOA/Work order and/or.
- f. Sign the Agreement AND / OR furnish the required Performance security.

I/We understand this Bid Securing Declaration shall cease to be valid if I am/we are not the successful Bidder, upon the earlier of (i) the receipt of your notification of the name of the successful Bidder; or (ii) thirty days after the expiration of the validity of my/our Bid.

Signed: (insert signature of person whose name and capacity are shown)

in the capacity of (insert legal capacity of person signing the Bid Securing Declaration)

Name: (insert complete name of person signing the Bid Securing Declaration)

Duly authorized to sign the bid for an on behalf of (insert complete name of Bidder)

Dated on _____ day of _____ (insert date of signing)

Corporate Seal (where appropriate)

ANNEXURE I

PRICE SCHEDULE (BILL OF QUANTITIES)

NAME OF WORK: "Providing of Power supply points for portable Mist Cannon at B. No 10/11 areas and excavation of trench of 12 meters in length for rectification of damaged power supply cable of High Mast No. 32".

Sr. No	Description	Quantity	Unit	Rate/unit (Rs)	Amount (Rs)
1.	Clamping of 4 core x 25 sq.mm Aluminum armoured cable on wall with GI clamps at 1 meter spacing. (Cable will be supplied by Port).	120	RM		
2.	Laying of cable in excavated trench of size 0.4m wide and 0.8 m deep through GI pipe 3" dia. at road crossing. (GI pipe "B" class will be supplied by Port).	23	RM		
3.	Laying of cable on T-2 shed ramp through 3" dia. GI pipe with cementing on top (GI pipe "B" class to be supplied by Port).	05	RM		
4.	Excavation of cable trench of size 0.4mx0.8m deep in asphalted road and back filling.	35	RM		
5.	Supply, Installation and wiring of Distribution box mounted on MS angle stand 3 feet height, well grouted , containing 1 No. 4 pole, 32 Amps MCB, 1 No. 32 Amps 5-pin wall mounted type IP44, Industrial socket and provision of 1 no. 15 Amps switch socket point inside DB. (DB should be grey painted and outdoor type with provision of glands for 4-core, 25 sq.mm cable). Termination of 4 core X 25 sqmm cable in DB. Testing and commissioning.	07	Nos.		
TOTAL (Rs)					

In Words Rupees _____ **only,**
exclusive of GST.

Date:

Place:

Signature:

Name:

Address:

Office seal of firm:

Note:

- 1. The bidder shall quote the price exclusive of GST. Applicable GST shall be paid on the quoted price.**
- 2. Evaluation will be done only on the basic price.**
- 3. Payment will be made at actuals/ pro-rata basis**