

MORMUGAO PORT TRUST
ENGINEERING MECHANICAL DEPARTMENT

CME/XEN (E)/HL/M-11/17/1 80 -

09.06.2016

**SUB: AMMENDMENTS TO THE TENDER FOR" REPLACEMENT OF FIRE ALARM
SYSTEM INSTALLED AT ADMINISTRATIVE BUILDING"**

e-TENDER NO: CME/XEN(E)/M-11/2017/01

With reference to the various queries raised by the Bidders at the Pre-Bid meeting held on **07.06.2017** and those received by e-mail prior to the meeting, certain tender clauses have been amended and issued as an Addendum to the tender.

The Addendum shall be hosted on Port's Web site on **09/06/2017**

Meanwhile it is informed that the date for submission of the Tender and opening of Cover- I will be 20/06/2017 at 11.00Hrs.

All the prospective Bidders are kindly requested to take note of the above.


CHIEF MECHANICAL ENGINEER

Encl: 1) Addendum (1 Sheet)

MORMUGAO PORT TRUST
ENGINEERING MECHANICAL DEPARTMENT

**TENDER FOR" REPLACEMENT OF FIRE ALARM SYSTEM INSTALLED AT
ADMINISTRATIVE BUILDING"**

e-TENDER NO: CME/XEN(E)/M-11/2017/01

ADDENDUM

CORRECTIONS / ADDITIONS / DELETIONS, ETC...

[Total Number of Pages: 1]

NOTE:

1. Addendum is issued consequent to the discussions held at the Pre Bid Meeting on 07.06.2017. This "Addendum" should be read in conjunction with Tender Document reference no. CME/XEN(E)/M-11/2017/01
2. Consequential changes, arising out of this Addendum, will be deemed to have been effected, even if the same were not incorporated specifically in the Tender Document.
3. All other terms and conditions of the Tender Document will remain unchanged.
4. One set of this "Addendum", along with one set of Tender Document, shall be submitted along with the Techno-Commercial Offer (in Cover-I), with each page of it, duly signed and stamped, as token of acceptance.

SUB : “Replacement of Fire Alarm system installed at Administrative Building”

SI. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
1	2.3(1)	19	<p>Panel:DXc single loop Fire Alarm Control Panel, one loop card inbuild,198 addressable points (99 detectors+99 devices), 6*40 character blue crystal display with backlight illumination, 2 Sounder circuits, Kit Dxc Usb Upload Download Lead, with batteries, mountings & accessories. The panel shall be EN54 / Vds Certification. Including cable glands, screw ravel plugs etc complete.</p>	<p>You are requested to make the technical specification of Panel generic as DXc model is Brand specific. Also, the specification for Panel seems to be of old technology. As per the latest feature and as per the NFPA Guidelines also, The panel should have redundancy feature i.e C.P.U redundancy, Loop card redundant ,display is Touchscreen type and also as per the new technology, a single loop connecting upto 250 Addressable Devices in any combination .Kindly approve the latest features which is advance and better to your requirement.</p> <p>Addressable Short circuit breaker - 05 no's required for this system which is need in Morley IAS System Compulsorily.</p>	<ul style="list-style-type: none"> • Scope of work is upgradation of existing fire alarm system along with panel and detectors. Model of panel to be supplied is 'NOTIFIER NFS2-3030' or 'BOSCH FPA-5000'
2	2.3(6)	20	<p>2 core x 1.5 sq. mm zero halogen low smoke (FRLS) fire survival cable conforming to BS-6387 CWZ, LPCB certified complete.</p>	<p>We understand that we need to provide 2 Core x 1.5 sqmm FRLS Cable not Fire survival cable. Please confirm the same.</p> <p>We understand that the cables will lay on walls using saddles . Please confirm.</p> <p>We understand that , there is no underground and concealing work is envisaged. If it is require , then provide details with qty in both the soil (hard as well as soft soil) .</p>	<ul style="list-style-type: none"> • As per tender condition armoured2 Core x 1.5 sqmm FRLS Cable to be used. • Yes. Cables shall be laid on wall with saddles. • Existing cable will be used from panel to detectors on every floor ,if additional cable is required same will be laid on the wall with saddles.
3	11	7		<p>Can we avail the EMD & Security Deposit exemption benefit ?? Kindly confirm for the same. We are registered under NSIC,MSME ,</p>	<ul style="list-style-type: none"> • NSIC/MSME only for exemption of EMD. However no exemption for SD.
4				<p>MPT Provide Form 'C' for billing. Kindly confirm .</p>	<ul style="list-style-type: none"> • No 'C' form shall be provided by Port
5				<p>MPT provided Octrio exemption certificate, Excise duty benefit,CENVAT& Custom duty benefit, Kindly confirm.</p>	<ul style="list-style-type: none"> • The prices are offered as per BOQ. However,when Government implements GST, the same is applicable.